

CERTIFICATE OF CONFORMITY

This Certificate is issued to

ASSOCIATED ENTERPRISES (S) PTE LTD
Blk 28 Sin Ming Drive
#01-173
Singapore 575702

For Product Certification Scheme: Class 1

Product : **Portable Fire Extinguisher**
Brand : **PROTEC**
Model : **Refer to Appendix**
Country of Origin : **Singapore**
Product Details : **Refer to Appendix**

which has complied with the requirements of the scheme based on the following:

STANDARD(S)	TEST REPORT(S)
SS EN 3-7 : 2012	Refer to Appendix
SS EN 3-8 : 2012	
SS EN 3-9 : 2012	



Sze Thiam Siong (Mr)
General Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No

FSP-2013-0139-1

Date of Issue

05/06/2016

Date of Expiry

04/06/2019



This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com



The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.



CERTIFICATION
BODY

Appendix

Certificate No: FSP-2013-0139-1

Date of Issue: 05 Jun 2016

Product Details

Test Report(s)	
Test Report No.: 280703	Test Report No.: 275606
Test Report No.: 275449	Test Report No.: 277254
Test Report No.: 275448	Test Report No.: 277422
Test Report No.: 274193	Test Report No.: 285/7361051
Test Report No.: 275446	Test Report No.: 276639
Test Report No.: 275452	Test Report No.: 277253
Test Report No.: 275601	Test Report No.: 277261
Test Report No.: 275602	Test Report No.: 277257
Test Report No.: 275603	Test Report No.: 277258
Test Report No.: 277255	Test Report No.: 277260
Test Report No.: 277262	Test Report No.: 287032
Test Report No.: 277259	Test Report No.: 287378
Test Report No.: 280706	Test Report No.: 280708
Test Report No.: 280707	

Sze Thiam Siong (Mr)
General Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Amendments or additions to this appendix other than those authorized by SETSCO render the appendix invalid.

Product Details

Model No.	Type	Capacity	Fire Rating
PRO-2-FOAM	Foam (SP)	2 Litre	8A/55B
PRO-6-FOAM	Foam (SP)	6 Litre	21A/144B
PRO-9-FOAM	Foam (SP)	9 Litre	27A/233B
PRO-2-CD	Carbon Dioxide	2 KG	34B
PRO-2-CD-AL	Carbon Dioxide	2 KG	34B
PRO-5-CD	Carbon Dioxide	5 KG	70B
PRO-5-CD-AL	Carbon Dioxide	5 KG	70B
PRO-1-DC	ABC Powder (SP)	1 KG	8A/34B
PRO-2-DC	ABC Powder (SP)	2 KG	13A/89B
PRO-3-DC	ABC Powder (SP)	3 KG	21A/113B
PRO-4-DC	ABC Powder (SP)	4 KG	27A/144B
PRO-6-DC	ABC Powder (SP)	6 KG	43A/233B
PRO-9-DC	ABC Powder (SP)	9 KG	55A/233B
PRO-12-DC	ABC Powder (SP)	12 KG	55A/233B
PRO-6-W	Water (SP)	6 Litre	13A
PRO-9-W	Water (SP)	9 Litre	21A
PRO-2-WC	Wet Chemical (SP)	2 Litre	8A/34A/25F
PRO-3-WC	Wet Chemical (SP)	3 Litre	13A/70B/40F
PRO-6-WC	Wet Chemical (SP)	6 Litre	21A/113B/75F



Sze Thiam Siong (Mr)
General Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925