

CERTIFICATE OF CONFORMITY

This Certificate is issued to

ASSOCIATED ENTERPRISES (S) PTE LTD

Blk 28 Sin Ming Drive

#01-173

Singapore 575702

For Product Certification Scheme: Class 1

Product : Fire Hose Reel
Brand : AE
Model : Refer to Appendix
Country of Origin : Singapore
Product Details : Refer to Appendix

which has complied with the requirements of the scheme based on the following:

STANDARD(S)	TEST REPORT(S)
BS EN 671-1: 2012	54S023240/1/YAS 54S023240/2/YAS 54S064107/TSM 719182730-MEC10/01-TSM 719182730-MEC10/02-TSM 2411/7388374



Sze Thiam Siong (Mr)
General Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No	Date of Issue	Date of Expiry
FSP-2010-0001	27/09/2016	26/09/2019



This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.





Product Details

Fixed Type Hose Reel	
Model	Description
50-N	19mm, manually operated fixed type fire hose reel
55-N	25mm, manually operated fixed type fire hose reel
60-A	19mm, automatic fixed type fire hose reel
65-A	25mm, automatic fixed type fire hose reel

Swing Type Hose Reel	
Model	Description
99-N	19mm, manually operated swinging type fire hose reel
100-N	25mm, manually operated swinging type fire hose reel
110-A	19mm, automatic swinging type fire hose reel
115-A	25mm, automatic swinging type fire hose reel

Sze Thiam Siong (Mr)
General Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925