

# CERTIFICATE OF CONFORMITY

This Certificate is issued to

**ASSOCIATED ENTERPRISES (S) PTE LTD**  
**Block 28, Sin Ming Drive**  
**#01-173/177**  
**Singapore 575702**

**For Product Certification Scheme: Type 5**

**Product** : **Fire Extinguisher**  
**Brand** : **PROTEC**  
**Model** : **Refer to Appendix**  
**Country of Origin** : **Assembled in Singapore**  
**Product Details** : **Refer to Appendix**

which has complied with the requirements of the scheme based on the following:

| <b>STANDARD(S)</b> | <b>TEST REPORT(S)</b>                    |
|--------------------|--|
| SS EN 3-7: 2012    | APRAGAZ Test Report No.: 157099          |
| SS EN 3-8: 2012    | APRAGAZ Test Report No.: EN 11961/TIANBO |
| SS EN 3-9: 2012    | APRAGAZ Test Report No.: EN 11928        |
|                    | APRAGAZ Test Report No.: EN 11929        |
|                    | APRAGAZ Test Report No.: EN 11930        |
|                    | APRAGAZ Test Report No.: EN 11386/TIANBO |
|                    | APRAGAZ Test Report No.: EN 11387/TIANBO |
|                    | SETSO Test Report No.: MM-8500040727/CY  |
|                    | MPA Test Report No.: 20181239/TB02       |
|                    | MPA Test Report No.: 20181239/TB03       |
|                    | MPA Test Report No.: 20181239/TB01       |
|                    | APRAGAZ Test Report No.: EN11923         |
|                    | APRAGAZ Test Report No.: EN11924         |
|                    | APRAGAZ Test Report No.: 138788-A        |
|                    | APRAGAZ Test Report No.: EN11925         |
|                    | APRAGAZ Test Report No.: EN11926         |



**Sze Thiam Siong (Mr)**  
Chief Executive Officer  
SETSCO Services Pte Ltd  
18 Teban Gardens Crescent  
Singapore 608925

**Certificate No**  
**FSP-2018-0730**

**Date of Issue**  
**29/10/2018**

**Date of Last Revision**  
**23/04/2019**

**Date of Expiry**  
**28/10/2023**



This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at [www.setsco.com](http://www.setsco.com)



The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.

| <b>Model</b> | <b>Product Details</b>                   | <b>Fire Rating</b> |
|--------------|--|--------------------|
| PRO-1-DC     | 1.0 kg ABC Fire Extinguisher             | 8A, 34B            |
| PRO-2-DC     | 2.0 kg ABC Fire Extinguisher             | 13A, 89B           |
| PRO-3-DC     | 3.0 kg ABC Fire Extinguisher             | 13A, 113B          |
| PRO-4-DC     | 4.0 kg ABC Fire Extinguisher             | 21A, 144B          |
| PRO-6-DC     | 6.0 kg ABC Fire Extinguisher             | 55A, 233B          |
| PRO-9-DC     | 9.0 kg ABC Fire Extinguisher             | 55A, 233B          |
| PRO-12-DC    | 12.0 kg ABC Fire Extinguisher            | 55A, 233B          |
| PRO-2-CD     | 2.0 kg CO <sub>2</sub> Fire Extinguisher | 34B                |
| PRO-5-CD     | 5.0 kg CO <sub>2</sub> Fire Extinguisher | 89B                |
| PRO-6-W      | 6.0 L Water Fire Extinguisher            | 13A                |
| PRO-9-W      | 9.0 L Water Fire Extinguisher            | 21A                |
| PRO-6-FOAM   | 6.0 L Foam Fire Extinguisher             | 21A, 183B          |
| PRO-9-FOAM   | 9.0 L Foam Fire Extinguisher             | 27A, 233B          |



**Sze Thiam Siong (Mr)**  
Chief Executive Officer  
SETSCO Services Pte Ltd  
18 Teban Gardens Crescent  
Singapore 608925

**Certificate No**  
**FSP-2018-0730**

**Date of Issue**  
**29/10/2018**

**Date of Last Revision**  
**23/04/2019**

**Date of Expiry**  
**28/10/2023**

*Amendments or additions to this appendix other than those authorized by SETSCO render the appendix invalid.*