

# CERTIFICATE OF CONFORMITY

This Certificate is issued to

**ASSOCIATED ENTERPRISES (S) PTE LTD**

**(UEN No.: 197900283H)**

**Block 28 Sin Ming Drive, #01-173/177, Singapore 575702**

**For Product Certification Scheme: Type 5**

**Product : Fire Extinguisher**

**Brand : PROTEC**

**Model : PRO-2-CD, PRO-5-CD**

**Country of Origin : Singapore**

**Product Details : Carbon dioxide, CO<sub>2</sub> type of extinguisher**

Model	Product Details	Fire Rating
PRO-2-CD	2kg CO <sub>2</sub> fire extinguisher	34B
PRO-5-CD	5kg CO <sub>2</sub> fire extinguisher	89B

which has complied with the requirements of the scheme based on the following:

**STANDARD(S)**

SS EN 3-7: 2012

SS EN 3-9: 2012

**TEST REPORT(S)**

APRAGAZ Test Report No.: EN 11386/TIANBO

APRAGAZ Test Report No.: EN 11387/TIANBO

APRAGAZ Test Report No.: EN 138788-A

SETSCO Test Report No.: MM-8500040727/CY

**Detailed configuration and installation shall be referenced to the certified report(s) stated above.**



**Dixon Ng (Mr)**  
Program Manager  
SETSCO Services Pte Ltd  
18 Teban Gardens Crescent  
Singapore 608925

**Certificate No**

**FSP-2020-1023**

**Date of Original Issue**

**29/10/2018**

**Date of Issue**

**10/11/2020**

**Date of Expiry**

**28/10/2023**

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at [www.setsco.com](http://www.setsco.com)

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.