

CERTIFICATE OF CONFORMITY

This Certificate is issued to

ASSOCIATED ENTERPRISES (S) PTE LTD

(UEN No.: 197900283H)

28 Sin Ming Drive, #01-173/177, Singapore 575702

For Product Certification Scheme: Type 5

Product : Fire Extinguisher

Brand : PROTEC

**Model : PRO-1-DC, PRO-2-DC, PRO-3-DC, PRO-4-DC,
PRO-6-DC, PRO-9-DC, PRO-12-DC**

Country of Origin : Singapore

**Product Details : Dry powder type fire extinguisher.
Refer to Appendix for details.**

which has complied with the requirements of the scheme based on the following:

STANDARD(S)	TEST REPORT(S)
SS EN 3-7: 2012	SETSCO Test Report No.: MM-8500040727/CY
EN 3-8: 2006	APRAGAZ Test Report No.: 157099
	APRAGAZ Test Report No.: EN11961/TIANBO
	APRAGAZ Test Report No.: EN11928
	APRAGAZ Test Report No.: EN11929
	APRAGAZ Test Report No.: EN11930
	MPA Dresden Test Report No.: 20181239/TB 01
	MPA Dresden Test Report No.: 20181239/TB 02
	MPA Dresden Test Report No.: 20181239/TB 03

Detailed configuration and installation shall be referenced to the certified report(s) stated above.



Dixon Ng (Mr)
Program Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No	Date of Issue	Date of Last Revision	Date of Expiry
FSP-2018-0730	29/10/2018	07/06/2021	28/10/2023

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.



Model	Product Details	Fire Rating
PRO-1-DC	1.0 kg ABC Fire Extinguisher	8A, 34B
PRO-2-DC	2.0 kg ABC Fire Extinguisher	13A, 89B
PRO-3-DC	3.0 kg ABC Fire Extinguisher	13A, 113B
PRO-4-DC	4.0 kg ABC Fire Extinguisher	21A, 144B
PRO-6-DC	6.0 kg ABC Fire Extinguisher	55A, 233B
PRO-9-DC	9.0 kg ABC Fire Extinguisher	55A, 233B
PRO-12-DC	12.0 kg ABC Fire Extinguisher	55A, 233B

Dixon Ng (Mr)
Program Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No	Date of Issue	Date of Last Revision	Date of Expiry
FSP-2018-0730	29/10/2018	07/06/2021	28/10/2023

Amendments or additions to this appendix other than those authorized by SETSCO render the appendix invalid.