

CERTIFICATE OF CONFORMITY

This Certificate is issued to

ASSOCIATED ENTERPRISES (S) PTE LTD

(UEN No.: 197900283H)

Blk 28 Sin Ming Drive, #01-173, Singapore 575702

For Product Certification Scheme: Type 5

Product : Fire Hose Reel

Brand : AE

**Model : FIG.50-N, FIG.55-N, FIG.60-A, FIG.65-A, FIG.99-N,
FIG.100-N FIG.110-A, FIG.115-A**

Country of Origin : Singapore

Product Details : Refer to Appendix for details.

which has complied with the requirements of the scheme based on the following:


STANDARD(S)

EN 671-1: 2012

TEST REPORT(S)

TUV SUD PSB Test Report No.: 7191177760-MEC18/01A-RAH
TUV SUD PSB Test Report No.: 7191177760-MEC18/01B-RAH
TUV SUD PSB Test Report No.: 7191177760-MEC18/01C-RAH
TUV SUD PSB Test Report No.: 7191177760-MEC18/01D-RAH
TUV SUD PSB Test Report No.: 7191177760-MEC18/01E-RAH
TUV SUD PSB Test Report No.: 7191177760-MEC18/01J-RAH
TUV SUD PSB Test Report No.: 7191177760-MEC18/01K-RAH
TUV SUD PSB Test Report No.: 7191177760-MEC18/01L-RAH

Detailed configuration and installation shall be referenced to the certified report(s) stated above.



Fiona Leong (Ms)
Program Manager
SETSCO Services Pte Ltd

Certificate No
FSP-2010-0001

Date of Issue
12/07/2024

Date of Expiry
26/09/2029

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.



Fixed Type Fire Hose Reel

Model	Description
FIG.50-N	19mm manual fixed type
FIG.55-N	25mm manual fixed type
FIG.60-A	19mm automatic fixed type
FIG.65-A	25mm automatic fixed type

Swing Type Fire Hose Reel

Model	Description
FIG.99-N	19mm manual swing type
FIG.100-N	25mm manual swing type
FIG.110-A	19mm automatic swing type
FIG.115-A	25mm automatic swing type

Fiona Leong (Ms)
Program Manager
SETSCO Services Pte Ltd

Certificate No
FSP-2010-0001

Date of Issue
12/07/2024

Date of Expiry
26/09/2029

Amendments or additions to this appendix other than those authorized by SETSCO render the appendix invalid.